INSTITUTE OF CERAMICS
AND BUILDING MATERIALS

DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW
DEPARTMENT OF GLASS TECHNOLOGY

30-702 Cracow, Lipowa 3 Str
phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+48 12) 423 58 36
www.icimb.pl e-mail: info2_krakow@icimb.pl

TESTING CERTIFICATE No. 2064/ICiMB/ST/14

Subject of testing ***Insulating glass units dual chamber construction 4ClimaGuard Premium/12/4 Float/12/4ClimaGuard Premium with Argon delivered by DRUTEX S.A. z Bytowa***

Principal orderer ***DRUTEX S.A.***
ul. Lęborska 31, 77 - 100 Bytów

Type of testing ***Determination of thermal trasmittance coefficient "U" according to the standard PN-EN 674:2011 "Glass in building. Determination of thermal transmittance (U value). Guarded hot plate method".***

Judgement ***Thermal transmittance „U" of tested insulating glass units construction 4ClimaGuard Premium/12/4Float/12/4ClimaGuard Premium with Argon in interglass space amount to U=0,7 W/(m^2 ·K).***

The basic of judgement: ***Test Report No. 087.a.FW.14.AK z 31.07.2014***

Responsible person
for the test

Z-ca KIEROWNIKA
Zakładu Technologii Szkła

mgr inż. Anna Balon-Wróbel

Cracow, date ***1.08.2014***

DYREKTOR ODDZIAŁU

dr inż. Henryk Szeląg
Director

This certificate is valid to: 1.08.2017